


**1,500 GALLON TOP-SEAM
CONCRETE SEPTIC TANK**

NOT TO SCALE

SCALE: 1-INCH = 5-FEET



20" Diameter Polylok Cover

2" Polystyrene Insulation

20" Diameter Polylok Riser

INLET INV. ELEV. = 574.8'

5'

1'-0"

3'


OUTLET INV. ELEV. = 574.6'

SECTION

- ## 5-OUTLET ROUND CONCRETE DISTRIBUTION BOX

NOT TO SCALE

SCALE: 1-INCH = 2-FEET



WASTEWATER DISPOSAL SYSTEM CONSTRUCTION AND MAINTENANCE NOTES

1. THE IN-GROUND WASTEWATER SYSTEM SHALL BE CONSTRUCTED IN ACCORDANCE WITH THE STATE OF VERMONT PERMITTED DESIGN DRAWINGS.
2. THE WASTEWATER DISPOSAL SYSTEM LOCATION SHALL BE STAKED OUT BY THE DESIGNER PRIOR TO START OF CONSTRUCTION.
3. THE DESIGNER SHALL BE NOTIFIED AT LEAST 48 HOURS IN ADVANCE FOR INSPECTIONS OF THE SEPTIC TANK, PREPARATION OF THE ABSORPTION TRENCHES PRIOR TO PLACING THE SYSTEM STONE AND PRIOR TO FINAL COVERING OF THE WASTEWATER SYSTEM.
4. THE CONTRACTOR SHALL ADHERE TO VERMONT OCCUPATIONAL HEALTH AND SAFETY GUIDELINES FOR EXCAVATING AND TRENCH EXCAVATIONS.
5. SEPTIC TANK EFFLUENT FILTER SHOULD BE REMOVED AND RINSED BACK INTO THE SEPTIC TANK ONCE PER YEAR.
6. THE SEPTIC TANK SHALL BE INSPECTED ANNUALLY AND PUMPED OUT EVERY 3 YEARS.
7. FOLLOWING THE IN-GROUND WASTEWATER SYSTEM INSTALLATION, FINISH GRADE SHALL BE SEEDED AND MULCHED WITH A CONSERVATION GRASS SEED MIX.