



Tyler Machia &lt;tmachia@richmondvt.gov&gt;

---

**Driveway at 809 Milkweed Ln.**

1 message

**Dennis Gile** <richmondfiredept@richmondvt.gov>

Sun, Apr 10, 2022 at 6:14 PM

To: Ravi Venkataraman &lt;rvenkataraman@richmondvt.gov&gt;, Tyler Machia &lt;tmachia@richmondvt.gov&gt;

Cc: Gerald Levesque &lt;geraldlevesque@ymail.com&gt;, Dennis Gile &lt;richmondfiredept@richmondvt.gov&gt;

To whom it may concern: According to section 6.2 (f) of the Public works driveways need not exceed a 12% grade. Richmond Fire Department supports the need for driveways to not exceed a 12% grade. Our fire apparatus cannot access homes or driveways that exceed the 12% grade due to steepness. Therefore the Richmond Fire Department cannot guarantee Fire Protection on said homes. Richmond Fire Department: Chief Dennis Gile .