



Suzanne Mantegna &lt;smantegna@richmondvt.gov&gt;

---

**DRB app in FHOD Richmond**

---

**Medash, Kyle** <Kyle.Medash@vermont.gov>  
To: Suzanne Mantegna <smantegna@richmondvt.gov>

Thu, Oct 1, 2020 at 12:36 PM

Hi Suzanne,

Per the applicants response, the porch steps have been adequately anchored to resist floatation, collapse, or lateral movement during the base flood discharge. The mudroom and porch additions are constructed to meet the requirements of the NFIP and Town bylaw for development located in the SFHA.

The flood vents are designed and certified by a qualified engineer and meet the requirements of the NFIP and Town bylaw for development located in the SFHA. When reviewing the elevation certificate this was unclear from the provided information and wanted to confirm. Please let me know if you, the DRB, or the applicant has any questions or would like to discuss further.

Thanks,

Kyle Medash

Regional Floodplain Manager

Vermont Department of Environmental Conservation

802.490.6154



[Quoted text hidden]