



Kayla Vaccaro &lt;kvaccaro@richmondvt.gov&gt;

---

## Richmond Drop Off

---

**Medash, Kyle** <Kyle.Medash@vermont.gov>  
To: Kayla Vaccaro <kvaccaro@richmondvt.gov>  
Cc: Tyler Machia <tmachia@richmondvt.gov>

Wed, Apr 13, 2022 at 4:24 PM

Hi Kayla/Tyler,

The attached site plan appears to contain the required information meet the application submission requirements outlined in Section 6.8.17 (b), and the proposal intends to meet the development standards outlined in Section 6.8.16. As a condition of the permit, I'd recommend requiring as-built documentation confirming the use of flood resistant materials, wet-floodproofing details, and electrical installation to document compliance with Section 6.8.16. Please let me know if you have any questions. These comments are offered in accordance with 24 VSA §4424.

Respectfully,



---

**Kyle Medash** | Western Floodplain Manager

Vermont Agency of Natural Resources | Department of Environmental Conservation

Watershed Management Division, Rivers Program

450 Asa Bloomer State Office Building, [88 Merchants Row](#) | Rutland, VT 05701-5903

802-490-6154 cell

[kyle.medash@vermont.gov](mailto:kyle.medash@vermont.gov)

---

**From:** Kayla Vaccaro <kvaccaro@richmondvt.gov>  
**Sent:** Wednesday, April 13, 2022 11:41 AM  
**To:** Medash, Kyle <Kyle.Medash@vermont.gov>  
**Cc:** Tyler Machia <tmachia@richmondvt.gov>  
**Subject:** Re: [External] RE: Richmond Drop Off

**EXTERNAL SENDER: Do not open attachments or click on links unless you recognize and trust the sender.**

[Quoted text hidden]



---

**081-01 Casella Waste Systems\_Richmond Site\_PLANS 2022-04-11-C-1.0.pdf**  
308K