



1. SEPTIC TANK SHALL BE SET LEVEL ON A MINIMUM OF SIX INCHES OF COMPACTED GRANULAR BASE.
2. AN INLET TEE BAFFLE IS REQUIRED.
3. IF WATER-PROOF BOOTED CONNECTIONS ARE NOT USED, ALL PIPE PENETRATIONS SHALL BE SEALED WITH A "WATER PLUG" NON-SHRINK HYDRAULIC CEMENT.
4. EFFLUENT FILTER ACCESS SHALL BE COMPLETED FLUSH WITH FINISH GRADE.

NOT TO SCALE



- NOTES:

1. PUMP STATION SHALL BE SET LEVEL ON A MINIMUM OF SIX INCHES OF COMPACTED GRANULAR BASE.
2. PUMP STATION SECTIONS SHALL HAVE BUTYL RUBBER JOINT SEALER.
3. IF WATER-PROOF BOOTED CONNECTIONS ARE NOT USED, ALL PIPE PENETRATIONS SHALL BE SEALED WITH A "WATER PLUG"-NON-SHRINK HYDRAULIC CEMENT.
4. ON/OFF FLOAT SWITCH TO BE SET WITH A 6-INCH SWING SETTING TO PROVIDE A 135 GALLON DRAIN FILL TIME.
5. HIGH WATER LEVEL ALARM AND PUMP STATION SHALL BE WIRED BY A LICENSED ELECTRICIAN.
6. THE HIGH WATER LEVEL ALARM SHALL BE MOUNTED AT A VISIBLE LOCATION.
7. THE EFFLUENT PUMP SHALL BE CAPABLE OF 32 GPM VS. 19 TDH.

NOT TO SCALE

NOT TO SCALE

