

Richmond Water Resources Department

VERMONT GROUNDWATER SYSTEM #5084 DAILY TEST RESULTS Month **January** 2025

Date	Meter	gallons produced	Finished Water Entering System			Endyne FL Result
			FL Lev	Entry Point Free CL2	PH Out	On Date Sampled
Sample Location			Waterhouse Tap	Waterhouse Tap	Waterhouse Tap	From The
Target Range			0.6 - 1.0 mg/L	0.8 - 4.0 mg/L	Minimum of 7.0	0.6-1.0 mg/L
Dec 31 #->	2,643,000					
<b>1</b>	2,744,200	101,200	0.82	1.02	7.66	
<b>2</b>	2,764,000	19,800	0.80	0.89	7.66	0.65
<b>3</b>	2,848,000	84,000	0.82	0.90	7.67	
<b>4</b>	2,926,400	78,400	0.78	0.79	7.67	
<b>5</b>	2,980,700	54,300	0.80	1.00	7.68	
<b>6</b>	3,038,300	57,600	0.81	1.06	7.67	
<b>7</b>	3,080,700	42,400	0.83	0.79	7.66	0.61
<b>8</b>	3,141,200	60,500	0.66	0.74	7.70	
<b>9</b>	3,230,800	89,600	0.66	0.56	7.68	
<b>10</b>	3,262,000	31,200	0.70	0.63	7.67	
<b>11</b>	3,345,600	83,600	0.72	0.67	7.67	
<b>12</b>	3,383,000	37,400	0.70	0.68	7.66	
<b>13</b>	3,453,800	70,800	0.55	1.84	7.67	
<b>14</b>	3,500,000	46,200	0.58	1.60	7.67	
mission - <b>15</b>	3,559,900	59,900	0.63	0.81	7.64	0.41
<b>16</b>	3,609,400	49,500	0.64	0.60	7.63	
<b>17</b>	3,694,300	84,900	0.66	1.14	7.66	
<b>18</b>	3,740,000	45,700	0.70	1.11	7.65	
<b>19</b>	3,798,600	58,600	0.71	1.11	7.62	
<b>20</b>	3,857,600	59,000	0.66	0.92	7.68	
<b>21</b>	3,879,300	21,700	0.68	0.99	7.63	
<b>22</b>	3,989,800	110,500	0.79	0.96	7.66	
<b>23</b>	4,050,200	60,400	0.76	0.96	7.75	
<b>24</b>	4,075,800	25,600	0.77	0.85	7.61	0.53
<b>25</b>	4,180,700	104,900	0.77	0.81	7.69	
<b>26</b>	4,180,700	0	0.84	0.73	7.67	
<b>27</b>	4,270,300	89,600	0.77	0.78	7.62	
<b>28</b>	4,327,100	56,800	0.70	0.72	7.62	
<b>29</b>	4,348,000	20,900	0.76	0.74	7.60	
<b>30</b>	4,457,100	109,100	0.89	0.87	7.66	
<b>31</b>	4,457,500	400	0.86	0.66	7.68	
<b>Total</b>		1,814,500				
<b>Ave.</b>		58,532	0.74	0.90	7.66	0.55
<b>Max.</b>		110,500	0.89	1.84	7.75	0.65
<b>Min</b>		0	0.55	0.56	7.60	0.41

Vermont Monthly Operations Report For Groundwater Systems  
And Systems Purchasing Groundwater

**January**

**2025**

Name of System: Richmond Water Resources Department

WSID # : 5084      Town : Richmond

Brad Snow Operator, Phone work--> 434 - 2178 Phone home--> 316-2326

A master meter is installed and functioning which records daily production

All water quality compliance analysis results have been reported to the Water Supply Division.

See attached for production information and results of daily parameter testing.

I certify, as the owner or authorized representative of this Water System, that I have completed this form, or reviewed it if completed by another, and that I have taken the necessary steps to ensure the information shown is correct. In making this certification, I understand that civil and/or criminal penalties may be imposed for submitting false information.

Prepared by Brad Snow, Class 3 Public Water System Operator # OP05111

Signature  Date 1/31/25

Approved by Josh Arneson, Richmond Town Manager and Authorized Representative

Signature  Date 1/31/25

Notes: