

Richmond Water Resources Department						
VERMONT GROUNDWATER SYSTEM #5084 DAILY TEST RESULTS				Month	Sep-25	
		gallons produced	Finished Water Entering System			Endyne FL Result
Date	Meter		FL Lev	Entry Point Free CL2	PH Out	On Date Sampled
Sample Location			Waterhouse Tap	Waterhouse Tap	Waterhouse Tap	From The
						Waterhouse Tap
Target Range			0.6 - 1.0 mg/L	0.8 - 4.0 mg/L	Minimum of 7.0	0.6-1.0 mg/L
August 31 #-	16,518,700					
1	16,619,000	100,300	0.80	1.19	7.62	
2	16,624,600	5,600	0.77	1.08	7.63	0.72
3	16,714,700	90,100	0.70	1.49	7.61	
4	16,760,800	46,100	0.82	1.32	7.60	
5	16,835,500	74,700	0.81	1.28	7.60	
6	16,890,300	54,800	0.84	1.04	7.61	
7	16,918,300	28,000	0.83	1.07	7.62	
8	17,010,500	92,200	0.81	1.25	7.66	
9	17,025,400	14,900	0.75	1.37	7.67	0.72
10	17,132,700	107,300	0.78	1.48	7.66	
11	17,150,100	17,400	0.75	1.11	7.66	
12	17,248,600	98,500	0.84	1.46	7.65	
13	17,279,500	30,900	0.76	1.15	7.66	
14	17,378,700	99,200	0.84	1.28	7.62	
15	17,392,400	13,700	0.77	1.03	7.63	
16	17,469,300	76,900	0.75	1.45	7.66	
17	17,540,000	70,700	0.96	1.12	7.63	
18	17,548,500	8,500	0.78	0.98	7.62	
19	17,683,900	135,400	0.80	1.27	7.66	
20	17,700,800	16,900	0.73	1.62	7.68	
21	17,794,300	93,500	0.86	1.10	7.71	
22	17,794,300	0	0.72	1.05	7.71	
23	17,886,800	92,500	0.83	1.24	7.62	
24	17,922,600	35,800	0.78	1.08	7.65	
25	17,996,300	73,700	0.80	1.34	7.65	
26	18,048,400	52,100	0.86	0.98	7.66	
27	18,110,600	62,200	0.70	1.39	7.67	
28	18,168,900	58,300	0.75	1.16	7.68	
29	18,183,600	14,700	0.76	1.36	7.71	
30	18,288,600	105,000	0.72	1.41	7.72	
Total		1,769,900				
Ave.		57,094	0.79	1.24	7.65	0.72
Max.		135,400	0.96	1.62	7.72	0.72
Min		0	0.70	0.98	7.60	0.72

Vermont Monthly Operations Report For Groundwater Systems
And Systems Purchasing Groundwater

September

2025

Name of System: Richmond Water Resources Department

WSID # : 5084 Town : Richmond

Brad Snow Operator, Phone work--> 434 - 2178 Phone home--> 316-2326

A master meter is installed and functioning which records daily production

All water quality compliance analysis results have been reported to the Water Supply Division.


See attached for production information and results of daily parameter testing.

I certify, as the owner or authorized representative of this Water System, that I have completed this form, or reviewed it if completed by another, and that I have taken the necessary steps to ensure the information shown is correct. In making this certification, I understand that civil and/or criminal penalties may be imposed for submitting false information.

Prepared by Brad Snow, Class 3 Public Water System Operator # OP05111

Signature  Date 10/1/25

Approved by Josh Arneson, Richmond Town Manager and Authorized Representative

Signature  Date 10/2/25

<p>Notes:</p>
