

Richmond Water Resources Department  
VERMONT GROUNDWATER SYSTEM #5084 DAILY TEST RESULTS    Month    Nov-25

		gallons produced	Finished Water Entering System			Endyne FL Result
Date	Meter		FL Lev	Entry Point Free CL2	PH Out	On Date Sampled
Sample Location			Waterhouse Tap	Waterhouse Tap	Waterhouse Tap	From The
Target Range			0.6 - 1.0 mg/L	0.8 - 4.0 mg/L	Minimum of 7.0	0.6-1.0 mg/L
Oct. 31 #->	20,098,900					
1	20,135,200	36,300	0.74	0.96	7.83	
2	20,218,700	83,500	0.71	1.08	7.97	
3	20,256,600	37,900	0.86	0.92	7.94	0.61
4	20,321,400	64,800	0.68	0.85	7.90	
5	20,350,800	29,400	0.62	1.06	7.94	
6	20,409,600	58,800	0.67	1.00	7.93	
7	20,495,300	85,700	0.65	1.24	7.95	
8	20,582,700	87,400	0.79	1.28	7.87	
9	20,585,600	2,900	0.76	1.06	7.86	
10	20,694,800	109,200	0.81	1.30	7.86	0.59
11	20,740,200	45,400	0.75	1.04	7.90	
12	20,801,600	61,400	0.78	1.30	7.97	
13	20,843,600	42,000	0.81	1.14	7.93	
14	20,933,800	90,200	0.85	1.15	7.89	
15	20,990,800	57,000	0.80	1.13	7.90	
16	21,046,800	56,000	0.85	1.15	7.87	
17	21,117,100	70,300	0.81	1.18	7.89	
18	21,124,500	7,400	0.91	1.07	7.87	0.74
19	21,241,800	117,300	0.92	1.16	7.86	
20	21,281,600	39,800	0.92	1.36	7.85	
21	21,344,200	62,600	0.83	1.25	7.85	
22	21,420,500	76,300	0.86	1.20	7.85	
23	21,427,900	7,400	0.81	1.29	7.85	
24	21,548,600	120,700	0.84	1.34	7.85	
25	21,559,300	10,700	0.78	1.15	7.60	New Probe
26	21,648,300	89,000	0.85	1.33	7.42	
27	21,692,300	44,000	0.84	1.24	7.37	
28	21,704,600	12,300	0.90	0.99	7.53	
29	21,811,400	106,800	0.93	1.30	7.50	
30	21,811,400	0	0.89	1.28	7.52	
Total		1,712,500				
Ave.		55,242	0.81	1.16	7.81	0.646666667
Max.		120,700	0.93	1.36	7.97	0.74
Min		0	0.62	0.85	7.37	0.59

Vermont Monthly Operations Report For Groundwater Systems  
And Systems Purchasing Groundwater

NOV

2025

Name of System: Richmond Water Resources Department

WSID # : 5084 Town : Richmond

Brad Snow Operator, Phone work--> 434 - 2178 Phone home--> 316-2326


A master meter is installed and functioning which records daily production

All water quality compliance analysis results have been reported to the Water Supply Division.


See attached for production information and results of daily parameter testing.

I certify, as the owner or authorized representative of this Water System, that I have completed this form, or reviewed it if completed by another, and that I have taken the necessary steps to ensure the information shown is correct. In making this certification, I understand that civil and/or criminal penalties may be imposed for submitting false information.

Prepared by Brad Snow, Class 3 Public Water System Operator # OP05111

Signature  Date 12/1/2025

Approved by Josh Arneson, Richmond Town Manager and Authorized Representative

Signature  Date 12/1/25

Notes: