

Richmond Water Resources Department VERMONT GROUNDWATER SYSTEM #5084 DAILY TEST RESULTS Month Dec-25					
Date	Meter	gallons produced	FL Lev	Entry Point Free CL2	PH Out
Sample Location		Waterhouse Tap	Waterhouse Tap	Waterhouse Tap	On Date Sampled From The
Target Range		0.6 - 1.0 mg/L	0.8 - 4.0 mg/L	Minimum of 7.0	0.6-1.0 mg/L
Nov 30 #->		13,026,800			
1	21,898,000	8,871,200	0.82	1.33	7.47
2	21,952,800	54,800	0.78	1.41	7.49
3	22,011,800	59,000	0.77	1.47	7.46
4	22,093,700	81,900	0.88	1.34	7.47
5	22,103,700	10,000	0.81	1.09	7.48
6	22,215,700	112,000	0.77	1.29	7.49
7	22,215,700	0	0.86	1.28	7.49
8	22,268,900	53,200	0.89	1.26	7.48
9	22,368,100	99,200	0.87	1.29	7.50
10	22,368,400	300	0.87	1.23	7.52
11	22,502,800	134,400	0.85	1.22	7.46
12	22,575,000	72,200	0.94	1.24	7.49
13	22,612,000	37,000	0.79	1.20	7.45
14	22,698,400	86,400	0.79	1.10	7.45
15	22,698,400	0	0.81	1.11	7.46
16	22,825,700	127,300	0.85	1.15	7.46
17	22,841,500	15,800	0.84	1.09	7.45
18	22,915,200	73,700	0.72	1.33	7.45
19	22,976,000	60,800	0.74	1.13	7.44
20	23,035,700	59,700	0.79	1.35	7.51
21	23,099,700	64,000	0.79	1.20	7.49
22	23,105,600	5,900	0.79	1.19	7.49
23	23,239,900	134,300	0.74	1.24	7.45
24	23,239,900	0	0.79	1.11	7.47
25	23,352,700	112,800	0.73	1.33	7.45
26	23,511,600	158,900	0.72	1.30	7.47
27	23,683,700	172,100	0.81	1.20	7.45
28	23,802,500	118,800	0.80	1.35	7.48
29	23,874,600	72,100	0.72	1.21	7.44
30	23,918,400	43,800	0.69	1.47	7.48
31	24,010,300	91,900	0.72	1.22	7.48
Total		10,983,500			
Ave.		354,306	0.80	1.25	7.47
Max.		8,871,200	0.94	1.47	7.52
Min		0	0.69	1.09	7.44

Hydrant Break

Vermont Monthly Operations Report For Groundwater Systems
And Systems Purchasing Groundwater

Dec 2025

Name of System: Richmond Water Resources Department

WSID # : 5084 Town : Richmond

Brad Snow Operator, Phone work--> 434 - 2178 Phone home--> 316-2326

A master meter is installed and functioning which records daily production

All water quality compliance analysis results have been reported to the Water Supply Division.

See attached for production information and results of daily parameter testing.

I certify, as the owner or authorized representative of this Water System, that I have completed this form, or reviewed it if completed by another, and that I have taken the necessary steps to ensure the information shown is correct. In making this certification, I understand that civil and/or criminal penalties may be imposed for submitting false information.

Prepared by Brad Snow, Class 3 Public Water System Operator # OP05111

Signature BS Date 1/2/25

Approved by Josh Arneson, Richmond Town Manager and Authorized Representative

Signature Josh Arneson Date 1/2/25

Notes: