



# TOWN OF RICHMOND

RICHMOND TOWN CENTER

203 Bridge Street, P.O. Box 285

Richmond, Vermont 05477



## Town of Richmond – Request for Proposals Installation of Electronic Water Meters

### Addendum #1

ISSUED 3/12/24

**Please indicate on envelope for submittal that the  
response includes Addendum #1**

#### Clarification on location of Meter Interface Units

- Meter Interface Units will be mounted in the interior of the customer's building.

#### Clarification on Backflow Preventer, Item #12 Backflow Preventer (5/8 x 3/4"), Item #13 Backflow Preventer (1")

- A Double Check Valve is the style of Backflow Preventer that will be installed in the above two items.

#### Clarification on Backflow Preventer, Item #14 Backflow Preventer (1 1/2"), Item #15 Backflow Preventer (2")

- A Reduced Pressure Zone Valve (RPZ) is the style of Backflow Preventer that will be installed in the above two items.

#### Removal of "Expansion tanks as needed due to the installation of a check valve" from the RFP

- The above item will not be part of the installation