

Vermont Monthly Operations Report For Groundwater Systems  
And Systems Purchasing Groundwater

**March**

**2023**

Name of System: Richmond Water Resources Department

WSID # : 5084      Town : Richmond

Allen Carpenter Operator, Phone work--> 434 - 2178 Phone home--> 888-2387

A master meter is installed and functioning which records daily production

All water quality compliance analysis results have been reported to the Water Supply Division.

See attached for production information and results of daily parameter testing.

I certify, as the owner or authorized representative of this Water System, that I have completed this form, or reviewed it if completed by another, and that I have taken the necessary steps to ensure the information shown is correct. In making this certification, I understand that civil and/or criminal penalties may be imposed for submitting false information.

Prepared by Allen Carpenter, Class 3 Public Water System Operator # OP04153

Signature Allen Carpenter Date 4/6/23

Approved by Josh Arneson, Richmond Town Manager and Authorized Representative

Signature [Signature] Date 4/6/23

Notes:
--------

Richmond Water Resources Department

VERMONT GROUNDWATER SYSTEM #5084 DAILY TEST RESULTS Month--> March 2023

Date	Meter	gallons produced	FL Lev	Entry Point	Fin.	System
				CL2	PH Out	Free CL2
FEB 31 #->	10288600					
1	10376000	87400	0.64	0.58	7.4	0.55
2	10403300	27300	0.64	0.63	7.1	0.28
3	10505300	102000	0.63	0.58	7.1	0.56
4	10518300	13000	0.59	0.74	7.4	0.42
5	10626200	107900	0.61	0.61	7.4	0.59
6	10652600	26400	0.59	0.43	7.2	0.57
7	10738600	86000	0.67	0.61	7.7	0.66
8	10768300	29700	0.63	0.65	7.5	0.52
9	10868700	100400	0.78	0.69	7.4	0.63
10	10902800	34100	0.63	0.61	7.2	0.55
11	11013900	111100	0.64	0.72	7.1	0.52
12	11051800	37900	0.63	0.67	7.2	0.48
13	11130800	79000	0.58	0.57	7.2	0.66
14	11171600	40800	0.59	0.74	7.4	0.55
15	11271300	99700	0.63	1.03	7.5	0.37
16	11311600	40300	1.00	0.47	7.3	0.40
17	11403600	92000	0.92	0.55	7.4	0.39
18	11438000	34400	0.80	0.79	7.4	0.43
19	11524800	86800	0.80	0.69	7.3	0.55
20	11548400	23600	0.87	0.71	7.3	0.53
21	11680300	131900	0.77	0.75	7.2	0.67
22	11693700	13400	0.83	0.68	7.3	0.49
23	11796000	102300	0.73	0.73	7.4	0.59
24	11815800	19800	0.75	0.76	7.3	0.53
25	11912300	96500	0.67	0.54	7.2	0.60
26	11946300	34000	0.71	0.60	7.3	0.49
27	12020200	73900	0.68	0.75	7.4	0.60
28	12050400	30200	0.71	0.72	7.4	0.57
29	12164500	114100	0.69	0.58	7.2	0.65
30	12166300	1800	0.68	0.65	7.0	0.05
31	12295000	128700	0.86	0.54	7.1	0.68
<b>Total</b>		2006400	21.95	20.4	226.3	16.13
<b>Ave.</b>		64723	0.71	0.66	7.30	0.52
<b>Max.</b>		131900	1.00	1.0	7.7	0.68
<b>Min</b>		1800	0.58	0.4	7.0	0.05

- New Batch FL

- New Batch FL

- New Batch FL