



Josh Arneson <jarneson@richmondvt.gov>

Fwd: fluoride levels

1 message

Kendall Chamberlin <kchamberlin@richmondvt.gov>
To: Josh Arneson <jarneson@richmondvt.gov>

Mon, Sep 26, 2022 at 7:57 PM

----- Forwarded message -----

From: **Kendall Chamberlin** <kchamberlin@richmondvt.gov>
Date: Mon, Jul 27, 2015 at 1:37 PM
Subject: Re: fluoride levels
To: Allen Carpenter <acarpenter@richmondvt.gov>

Yes, bump it up a little....

On Mon, Jul 27, 2015 at 12:53 PM, Allen Carpenter <acarpenter@richmondvt.gov> wrote:

----- Forwarded message -----

From: **Greaves, Linda** <Linda.Greaves@vermont.gov>
Date: Mon, Jul 27, 2015 at 10:41 AM
Subject: fluoride levels
To: Allen Carpenter <acarpenter@richmondvt.gov>

Hi,

I know you have had some bumps in the road in the last few months. I have been watching your fluoride levels and they are pretty low.

Can you raise the level up to 0.70 ppm?

Thanks,

Linda

Starting on July 27, 2015 my email address will be linda.greaves@vermont.gov.

Linda Greaves

RDH, BA, PBC

Vermont Department of Health

Office of Oral Health

[108 Cherry Street](#)

[Burlington, Vt 05402](#)

phone: Burlington [802-651-1635](tel:802-651-1635) (Tuesday & Wednesday)

phone: Morrisville [802-888-1350](tel:802-888-1350) (Mon.,Thurs.,Fri.)

Fax: 802-651-1634

<http://www.fluoridescience.org/>



Good Oral Health is a Part of Being Healthy

Hi Kendall today's numbers was 1.1ppm. The town center numbers Total 0.07, and free 0.04.