

Vermont Monthly Operations Report For Groundwater Systems  
And Systems Purchasing Groundwater

**AUGUST 2022**

Name of System: Richmond Water Resources Department

WSID # : 5084 Town : Richmond

Kendall Chamberlin, Supt., Phone work--> 434 - 2178 Phone home--> 899 - 6830

A master meter is installed and functioning which records daily production

All water quality compliance analysis results have been reported to the Water Supply Division.

See attached for production information and results of daily parameter testing.

I certify, as the owner or authorized representative of this Water System, that I have completed this form, or reviewed it if completed by another, and that I have taken the necessary steps to ensure the information shown is correct. In making this certification, I understand that civil and/or criminal penalties may be imposed for submitting false information.

Prepared by Kendall Chamberlin, Class 3 Public Water System Operator # OP01027

Signature Kendall Chamberlin Supt. RWRD Date 9/8/22

Approved by Josh Arneson, Richmond Town Manager and Authorized Representative

Signature Josh Arneson Date 9/8/22

**VERMONT GROUNDWATER SYSTEM #5084 DAILY TEST RESULTS**      Month--> August 2022

<i>Date</i>	<i>Meter</i>	<i>gallons</i>	<i>Tot. Cl2</i>	<i>Free Cl2</i>	<i>Flu. Lev.</i>	<i>gals in</i>	<i>PH in</i>	<i>PH out</i>	<i>Temp</i>
July 31 #->	96293100								
<b>1</b>	96293100	0	0.04	0.02	0.3	0.0	6.6	7.2	16.0
<b>2</b>	96293100	0	0.02	0.01	0.3	0.0	6.6	7.2	16.0
<b>3</b>	96438000	144900	0.24	0.23	0.3	5.0	6.6	7.2	16.0
<b>4</b>	96547700	109700	0.21	0.16	0.3	5.0	6.6	7.2	16.0
<b>5</b>	96653700	106000	0.24	0.16	0.3	3.0	6.6	7.2	16.0
<b>6</b>	96653700	0	0.06	0.02	0.3	0.0	6.6	7.2	16.0
<b>7</b>	96653700	0	0.03	0.01	0.3	0.0	6.6	7.2	16.0
<b>8</b>	96653700	0	0.02	0.01	0.3	0.0	6.6	7.2	16.0
<b>9</b>	96757500	103800	0.17	0.11	0.3	4.0	6.6	7.2	16.0
<b>10</b>	96879100	121600	0.19	0.15	0.3	6.0	6.6	7.2	16.0
<b>11</b>	96995500	116400	0.17	0.11	0.3	8.0	6.6	7.2	16.0
<b>12</b>	97015800	20300	0.14	0.06	0.3	0.0	6.6	7.2	16.0
<b>13</b>	97015800	0	0.03	0.01	0.3	0.0	6.6	7.2	16.0
<b>14</b>	97015800	0	0.03	0.01	0.3	0.0	6.6	7.2	16.0
<b>15</b>	97106900	91100	0.02	0.01	0.3	4.0	6.6	7.2	16.0
<b>16</b>	97225800	118900	0.14	0.09	0.3	7.0	6.6	7.2	16.0
<b>17</b>	97340100	114300	0.09	0.03	0.3	4.0	6.6	7.2	16.0
<b>18</b>	97344900	4800	0.07	0.05	0.3	0.0	6.6	7.2	16.0
<b>19</b>	97432000	87100	0.05	0.04	0.3	0.0	6.6	7.2	16.0
<b>20</b>	97496400	64400	0.20	0.17	0.3	0.0	6.6	7.2	16.0
<b>21</b>	97496400	0	0.14	0.10	0.3	10.0	6.6	7.2	16.0
<b>22</b>	97496400	0	0.03	0.01	0.3	0.0	6.6	7.2	16.0
<b>23</b>	97596300	99900	0.12	0.08	0.3	5.0	6.6	7.2	16.0
<b>24</b>	97712500	116200	0.17	0.11	0.3	6.0	6.6	7.2	16.0
<b>25</b>	97781400	68900	0.20	0.17	0.3	3.0	6.6	7.2	16.0
<b>26</b>	97883400	102000	0.15	0.08	0.3	0.0	6.6	7.2	16.0
<b>27</b>	97926000	42600	0.07	0.05	0.3	5.0	6.6	7.2	16.0
<b>28</b>	97954100	28100	0.18	0.15	0.3	0.0	6.6	7.2	16.0
<b>29</b>	98025400	71300	0.17	0.11	0.3	3.0	6.6	7.2	16.0
<b>30</b>	98080500	55100	0.23	0.15	0.3	0.0	6.6	7.2	16.0
<b>31</b>	98142500	62000	0.14	0.11	0.3	3.0	6.6	7.2	16.0
<b>Total</b>		1849400	3.76	2.58	9.3	81.0	204.6	223.2	496.0
<b>Ave.</b>		59658	0.12	0.08	0.3	2.6	6.6	7.2	16.0
<b>Max.</b>		144900	0.24	0.23	0.3	10.0	6.6	7.2	16.0
<b>Min</b>		0	0.02	0.01	0.3	0.0	6.6	7.2	16.0